

## Notice to Bidder

### Subject : Online Payment for Purchase of Bidding Documents

Due to the outbreak of COVID-19 in Thailand, please be informed of the online payment for purchase of bidding documents as follows:

- 1) Payment shall be made by bank transfer or telegraphic transfer to EGAT's account no. 109-6-01958-2 (swift code : KRTHTHBK), Krung Thai Bank Public Company Limited, Bangkrui Branch, Nonthaburi.

All bank charges and fees incurred by the payment of bidding documents shall be under the buyer's responsibility.

- 2) Download the Registration Form and fill out all necessary information by typing. (Complete data is required.)
- 3) Submit the fill-out Registration Form and the proof of payment from 1) to the email address of the in-charge officer and [procurement.tse@egat.co.th](mailto:procurement.tse@egat.co.th) in the CC. before 15.00 hrs. Bangkok Standard Time.
- 4) After the payment has been verified for approximately 3 working days, the in-charge officer will send the link for downloading the bidding documents together with a copy of the receipt to the purchaser's email address in the Registration Form. (Purchaser can contact for the original receipt when the situation resumes to normal.)

***\*\* Please note that this online payment process is a temporary measure due to the COVID-19 outbreak. The online payment process will be available until further notice from EGAT \*\****

\*\*\*\*\*

# Registration Form

Invitation to Bid No. TILS-L-02

(Two-envelope)

Supply and Construction of Transmission Line 500 kV Thung Song - Songkhla 3  
(from Thung Song to KM. 105)

Transmission System Improvement Project in Lower Southern Region to Enhance System Security

Available Duration for Purchasing : May 29, 2020 - July 3, 2020

Price of Bidding Documents : USD 480.- or THB 15,000.-

## Instructions

- 1) Payment shall be made by bank transfer or telegraphic transfer to EGAT's account no. 109-6-01958-2 (swift code : KRTHTHBK), Krung Thai Bank Public Company Limited, Bangkok Branch, Nonthaburi.
- 2) Fill out this Registration Form in English by typing. (Complete data is required.)
- 3) Submit the filled-out Registration Form and the proof of payment to the in-charge officer via email [somsit.s@egat.co.th](mailto:somsit.s@egat.co.th) (with cc. [procurement.tse@egat.co.th](mailto:procurement.tse@egat.co.th)) before 15.00 hrs. Bangkok Standard Time.
- 4) The in-charge officer will send the link for downloading the bidding documents together with a copy of the receipt to the purchaser's email address in the Registration Form, which will take approximately 3 working days. (Purchaser can contact for the original receipt when the situation resumes to normal.)

For Purchaser		TAX ID :	
No.	Receipt No. :	Date :	
Bidder's Name			
Address			
		Country :	
Name of Contact Person :		Tel.	Mobile No.
Email Address :			
Local Representative			
Address			
		Tax ID :	
Name of Contact Person :		Tel.	Mobile No.
Email Address :			
For Procurement Officer		Change of Bidder's Name	TAX ID :
Bidder's Letter No. :		Dated :	
New Bidder's Name			
Address			
		Country :	
Name of Contact Person :		Tel.	Mobile No.
Email Address :			
<b>Contact Information of In-charge Officer</b>			
Name	Mr. Somsit Supwilai		
Email address	<a href="mailto:somsit.s@egat.co.th">somsit.s@egat.co.th</a>		
Telephone No.	(66) 2436 0342		
Mobile No.	(66) 81 259 4857		



Invitation to Bid No. TILS-L-02

(Two-envelope)

**Supply and Construction of Transmission Line  
500 kV Thung Song - Songkhla 3 (from Thung Song to KM. 105)  
Transmission System Improvement Project in  
Lower Southern Region to Enhance System Security**

The Electricity Generating Authority of Thailand (EGAT) is calling for the subject Invitation to Bid to be financed by EGAT's fund. The escalation factor (K) for price adjustment is applied to this Bid.

**Place of Construction** : From Thung Song Substation (KM.0) to KM. 105 (approx. 105 kilometers)

**Medium Cost (including Value Added Tax and other expenses)**: THB 1,680,000,000.-

**Eligibility of Bidders**

1. The Bidder and the Equipment shall be named in EGAT Accepted List as specified in the bidding documents.
2. The Bidder shall be a juristic person who provides such services and shall not be named in the List of Work Abandoners published by the Permanent Secretary, Ministry of Finance, and/or in the Debarment List and/or in the List of Work Abandoners declared by EGAT.
3. The Bidder shall not be a Jointly Interested Bidder with other Bidders as from the date of EGAT's issuance of the Invitation, or shall not be a person who undertakes any action as an "Obstruction of Fair Price Competition" for this Invitation.
4. The Bidder shall not either be EGAT's consultant or involve in EGAT's consultancy company under this Invitation to Bid, or shall not have EGAT's personnel involved in his business as shareholder having voting right that can control his business, director, manager, officer, employee, agent, or consultant except those who are officially ordered by EGAT to act or participate therein.
5. The Bidder shall not be the person who is privileged or protected not to be taken any legal proceedings under Thai Court; Provided that such Bidder's government declares that such special privilege is waived.
6. The Bidder who is a joint venture or consortium shall carry out all the work under such formation from the time of bidding until the fulfillment of the Contract.

*Kamika Dhachalapat*

### Availability of Bidding Documents

Bidding Documents in CD-ROM will be available for examination of Bidder's Qualifications and purchase during 8:00 hrs. to 15:00 hrs., Bangkok Standard Time, as from May 29, 2020 to July 3, 2020 at USD 480.- or THB 15,000.- per copy, non-refundable, at the following address :

International Procurement Department - Transmission Segment  
(Room No. 1202/2, 12<sup>th</sup> Floor, Building Tor. 101)  
Procurement and Inventory Management Division  
Electricity Generating Authority of Thailand  
Bangkruai, Nonthaburi 11130, Thailand  
Telephone no. 66 2436 0342 .  
E-mail : [procurement.tse@egat.co.th](mailto:procurement.tse@egat.co.th)

Please find more details and download Registration Form for purchasing Bidding Documents at <http://www4.egat.co.th/fprocurement/biddingeng/>.

Payment can be made by a certified cheque or money order payable to EGAT or by a telegraphic transfer to EGAT's current account no. 109-6-01958-2 (swift code : KRTHTHBK), Krung Thai Bank Public Company Limited, Bangkruai Branch, Nonthaburi. All bank charges and fees incurred by the payment of bidding documents shall be under the buyer's responsibility.

Bidding Documents in CD-ROM will be either airmailed or airfreighted to the buyer at EGAT's expense upon receipt of the relevant remittance. In case the buyer requires the Bidding Documents to be sent by Express Mail Service (EMS), the charge will be at the buyer's expense.

### Delivery of Bids

Price and Technical Proposals shall be submitted at Room No. 1202/1, 12<sup>th</sup> Floor, Building Tor. 101 during 9:30 hrs. to 10:00 hrs., Bangkok Standard Time, August 4, 2020 and Technical Proposal will be opened publicly at 10:00 hrs.

ELECTRICITY GENERATING AUTHORITY OF THAILAND

May 22, 2020

*Kannika Dhachalupat*

(Mrs. Kannika Dhachalupat)

Chief, International Procurement Department - Transmission Segment



ประกาศการไฟฟ้าฝ่ายผลิตแห่งประเทศไทย  
เรื่อง ประกวดราคาจ้าง เลขที่ TILS-L-02  
(ประกวดราคา 2 ซอง)

การไฟฟ้าฝ่ายผลิตแห่งประเทศไทย (กฟผ.) มีความประสงค์จะจัดหาและจ้างก่อสร้างสายส่งไฟฟ้าแรงสูง 500 kV ท่งสง - สงขลา 3 (จากสถานีไฟฟ้าแรงสูงท่งสง ถึง กิโลเมตรที่ 105) สำหรับโครงการปรับปรุงระบบส่งไฟฟ้า บริเวณภาคใต้ตอนล่าง เพื่อเสริมความมั่นคงระบบไฟฟ้า โดยทำสัญญาแบบปรับราคาได้ (ค่า k) โดยใช้ขบประมาณ กฟผ.

**สถานที่ก่อสร้าง :** จากสถานีไฟฟ้าแรงสูงท่งสง (กิโลเมตรที่ 0) ถึง กิโลเมตรที่ 105 (ระยะทางประมาณ 105 กิโลเมตร)

**ราคากลาง (รวมภาษีมูลค่าเพิ่มและค่าใช้จ่ายอื่นๆ) :** 1,680,000,000.- บาท

**คุณสมบัติของผู้เสนอราคา**

1. ต้องเป็นผู้ประกอบการและพัสดุที่ผ่านการคัดเลือกคุณสมบัติเบื้องต้น ตามบัญชีรายชื่อที่ระบุในเอกสารประกวดราคา
2. ต้องเป็นนิติบุคคลผู้มีอาชีพรับจ้างตามประกวดราคาจ้างดังกล่าว และต้องไม่เป็นผู้ที่งานซึ่งปลัดกระทรวงการคลัง ได้แจ้งเวียนชื่อไว้ หรือต้องไม่เป็นผู้ที่ กฟผ. ห้ามติดต่อหรือห้ามเข้าเสนอราคา หรือต้องไม่เป็นผู้ที่ได้รับผลของการสั่งให้นิติบุคคลหรือบุคคลอื่นเป็นผู้ทำงานตามคำสั่ง กฟผ.
3. ต้องไม่เป็นผู้มีผลประโยชน์ร่วมกันกับผู้เสนอราคารายอื่น ณ วันประกาศประกวดราคาครั้งนี้เป็นต้นไป หรือต้องไม่เป็นผู้กระทำการอันเป็นการขัดขวางการแข่งขันราคาอย่างเป็นธรรมในการดำเนินการประกวดราคาครั้งนี้
4. ต้องไม่เป็นที่ปรึกษาของ กฟผ. หรือมีส่วนร่วมในบริษัทที่ปรึกษาของ กฟผ. ในงานนี้ หรือต้องไม่มีผู้ปฏิบัติงาน กฟผ. เข้าไปมีส่วนร่วมในกิจการของผู้เสนอราคา ไม่ว่าจะในฐานะผู้ถือหุ้นที่มีสิทธิควบคุมการจัดการ กรรมการ ผู้อำนวยการ ผู้จัดการ พนักงาน ลูกจ้าง ตัวแทน หรือที่ปรึกษา ยกเว้น ในกรณีที่ผู้ปฏิบัติงานได้รับคำสั่งอย่างเป็นทางการจาก กฟผ. ให้ไปปฏิบัติงานหรือเข้าร่วมในกิจการของผู้เสนอราคา
5. ต้องไม่เป็นผู้ได้รับเอกสิทธิ์หรือความคุ้มกัน ซึ่งอาจปฏิเสธไม่ยอมขึ้นศาลไทย เว้นแต่รัฐบาลของผู้เสนอราคาได้มีคำสั่งให้สละสิทธิ์และความคุ้มกันเช่นนั้น
6. ผู้ประสงค์เข้าประกวดราคาในนามของกิจการร่วมค้าหรือกิจการค้าร่วม (Joint Venture or Consortium) จะต้องดำเนินการทุกขั้นตอนของการประกวดราคาในนามของกิจการร่วมค้าหรือกิจการค้าร่วม ตั้งแต่การเสนอราคาจนถึงสิ้นสุดข้อผูกพันกับ กฟผ.

กรมการ ๑๓๓๓๓

### การขายเอกสารประกวดราคา

ผู้สนใจติดต่อขอทราบรายละเอียด เพื่อตรวจสอบคุณสมบัติของผู้เสนอราคา และขอซื้อเอกสารประกวดราคา ในราคาชุดละ 15,000.- บาท ได้ที่ แผนกจัดจ้างต่างประเทศสายงานระบบส่ง (ห้อง 1202/2 ชั้น 12 อาคาร ท.101) กองจัดซื้อจัดจ้างต่างประเทศสายงานระบบส่ง ฝ่ายจัดซื้อจัดจ้างและบริหารพัสดุ การไฟฟ้าฝ่ายผลิตแห่งประเทศไทย เชียงสะพานพระราม 7 จังหวัดนนทบุรี ในวันทำการระหว่างเวลา 08:00 น. ถึง 15:00 น. ตั้งแต่ วันที่ 29 พฤษภาคม 2563 ถึงวันที่ 3 กรกฎาคม 2563 หรือสอบถามทางโทรศัพท์ หมายเลข 0 2436 0342 หรือ อีเมล [procurement.tse@egat.co.th](mailto:procurement.tse@egat.co.th) ทั้งนี้ สามารถ download แบบฟอร์มลงทะเบียนผู้ซื้อเอกสารประกวดราคาได้ที่ เว็บไซต์ <http://www4.egat.co.th/fprocurement/biddingeng/>

### การยื่นซองประกวดราคา

กำหนดยื่นซองข้อเสนอด้านเทคนิคพร้อมซองราคา ในวันที่ 4 สิงหาคม 2563 เวลา 9:30 น. ถึง 10:00 น. และเปิดซองข้อเสนอด้านเทคนิคเวลา 10:00 น. ณ ห้อง 1202/1 ชั้น 12 อาคาร ท.101 การไฟฟ้าฝ่ายผลิตแห่งประเทศไทย เชียงสะพานพระราม 7 จังหวัดนนทบุรี

ประกาศ ณ วันที่ 22 พฤษภาคม 2563

กมลทิศา วิชาญกุล  
(นางกรรณิกา วิชาญกุล)

หัวหน้ากองจัดซื้อจัดจ้างต่างประเทศสายงานระบบส่ง

ตารางแสดงวงเงินงบประมาณที่ได้รับจัดสรรและราคากลาง(ราคาอ้างอิง)  
ในการจัดซื้อจัดจ้างที่มีใ้ใช้งานก่อสร้าง

1. ชื่อโครงการ ประกวตราคา เลขที่ TILS-L-02

งานจัดหาและจ้างก่อสร้างสายส่ง 500 kV ท่งสง - สงขลา 3 (จาก สฟ. ท่งสง ถึงกิโลเมตรที่ 105)

โครงการปรับปรุงระบบส่งไฟฟ้าบริเวณภาคใต้ตอนล่าง เพื่อเสริมความมั่นคงระบบไฟฟ้า

/หน่วยงานเจ้าของโครงการ ฝ่ายแผนงานและโครงการระบบส่ง การไฟฟ้าฝ่ายผลิตแห่งประเทศไทย

2. วงเงินงบประมาณที่ได้รับจัดสรร

โครงการปรับปรุงระบบส่งไฟฟ้าบริเวณภาคใต้ตอนล่าง เพื่อเสริมความมั่นคงระบบไฟฟ้า

งบประมาณ 35,400 ล้านบาท

3. วันที่กำหนดราคากลาง 13 กุมภาพันธ์ 2563 (วันที่ รวส. อนุมัติ )

ราคารวมภาษีมูลค่าเพิ่มและค่าใช้จ่ายอื่นๆ เป็นเงิน 1,680,000,000.00 บาท ราคา/หน่วย ตามเอกสารแนบ

4. แหล่งที่มาของราคากลาง

หลักเกณฑ์การกำหนดราคากลางการจัดซื้อและจัดจ้างงานก่อสร้างระบบส่งไฟฟ้าของสายงานระบบส่ง

5. รายชื่อเจ้าหน้าที่ผู้กำหนดราคากลาง

5.1 นายพิทักษ์ ปิ่นอนงค์ กวสส-ส.

5.2 นายสมปอง บวรธีระกิจชัย หบส-ส. กวสส-ส.

5.3 นางสาวสิรินยา ต้นสัจจา วศ.8 หบส-ส. กวสส-ส.

หมายเหตุ ค่าใช้จ่ายอื่นๆ ได้แก่ ค่าใช้จ่ายที่ กฟผ. ต้องจ่ายตามวิธีการพิจารณาเปรียบเทียบราคาที่กำหนดไว้

ในเอกสารประกวดราคา เช่น อกรักษาเข้า เป็นต้น



นางสาวอัสยา ช่างวิทยากร  
ทจตส-ท.

22 พ.ค. 2563

**DETAILS OF THE MEDIUM COST FOR BID NO. TILS-L-02**

**SCHEDULE 1 : 500 kV Thung Song - Songkhla 3 Transmission Line (105 km) (TS - KM.105)**

Description	Total (Baht)
1A : PRELIMINARY WORK	9,868,420.80
1B : TOWER FOUNDATIONS	271,882,968.00
1C : TOWERS	903,969,875.25
1D : INSULATOR STRING AND OVERHEAD GROUND WIRE ASSEMBLIES	249,610,200.00
1E : CONDUCTOR AND OVERHEAD GROUND WIRE	55,793,197.60
1F : LINE ACCESSORIES	28,203,060.00
1G : GROUNDING MATERIALS	6,067,862.56
1H : OPTICAL FIBER AND LINE ACCESSORIES	26,147,773.05
1N : TEST OF EQUIPMENT	3,680,000.00
1O : SUPPLY OF SERVICE OF VEHICLES	8,340,150.00
1P : SUPPLY OF SPARE EQUIPMENT	7,546,114.12
<b>Total for Schedule 1</b>	<b>1,571,109,621.38</b>
Adjusted Price (Import Duty & Tax + VAT)	109,977,673.50
<b>Total Price Schedule 1</b>	<b>1,681,087,294.88</b>

<b>MEDIUM COST OF BID NO. TILS-L-02</b>	<b>1,680,000,000.00</b>
---	-------------------------

*Oran*  
นางสาวอัสยา ช่างวิทยากร  
ทจตส-ท.  
22 พ.ค. 2563

*[Signature]*  
12 ml 63



**Important Information**  
**for**  
**Invitation to Bid No. TILS-L-02**

---

The purpose of this section is to inform the Bidders to **carefully study** the details of the revised terms and conditions in the bidding documents. The following provisions have been **recently revised** as stated hereunder:

**Article A-3. Eligibility of Bidders: General Requirements and Article B-8. Information to be Submitted with Bid**

Bidders shall provide written anti-corruption policies and guidelines as specified in Data Sheet.

**Article A-4. Eligibility of Bidders: Technical Requirements**

The Bidder shall be named in EGAT Accepted Bidders List for Supply and Construction of Transmission Line attached at the end of Section A. Invitation to Bid.

**Article F-10. Payment:**

If the Contractor requires the payment of foreign currency portion to be paid directly to the suppliers, he has to inform EGAT **which portion of the Contract Price, as stipulated in the term of payment of the Contract**, to be paid accordingly.

In case the local Contractor requires foreign currency or currencies to be paid directly to him, payment of such foreign currency or currencies will be made to the local Contractor in Thai Baht by using the **selling exchange rate** published by the Bank of Thailand on the **payment date** (previously stated as buying exchange rate on the bid opening date).

The number of days which payment for the first portion of foreign supply will be made after delivery, previously specified as 45 days, has been **deleted**.

**Article F-12. Liquidated Damages for Late Completion and Late Delivery:**

The limit of liquidated damages, previously specified that does not exceed 10%, has been **deleted**.

# DATA SHEET

for

## Invitation to Bid No. TILS-L-02

(Two-envelope)

---

This Section consists of provisions that are specific to each procurement and supplement the information or requirements included in Bidding Documents.

1. Article A-3. Eligibility of Bidders: General Requirements

The following requirement shall be added to item I.:

***“j. Bidders shall provide written anti-corruption policies and guidelines with respect to procurement and supplies according to the Notification of the Anti-Corruption Co-Operation Committee Concerning Minimum Standards of the Anti-Corruption Policies and Guidelines in Relation to Procurement and Supplies Required to be Implemented by the Business Operator, Section 19 of the Government Procurement and Supplies Management Act B.E. 2560 (A.D. 2017).”***

2. Article B-2. Bid Price

The price for the dismantled Equipment is not applicable in this invitation to bid.

3. Article B-3. Bid Security

The amount of bid security shall be USD 2,682,050.- or THB 84,000,000.-.

4. Article B-4. Validity of Bids

The validity of the bid shall be for two hundred seventy (270) Days from the date specified for opening of technical proposals.

5. Article B-8. Information to be Submitted with Bid

The following document shall be added to Article B-8. Information to be Submitted with Bid:

*y. Bidder's anti-corruption policies and guidelines in relation to procurement and supplies together with the completely filled out Anti-Corruption Compliance Checklist as provided.*

6. Article B-12. Evaluation and Comparison of Bids

Evaluation and comparison of Bids shall be as specified in Article B-12. Evaluation and Comparison of Bids.

**Anti-Corruption Compliance Checklist**

Bidders shall provide written anti-corruption policies and guidelines with respect to procurement and supplies pursuant to the Notification of the Anti-Corruption Co-Operation Committee Concerning Minimum Standards of the Anti-Corruption Policies and Guidelines in Relation to Procurement and Supplies Required to be Implemented by the Business Operator, in accordance with Section 19 of the Government Procurement and Supplies Management Act B.E. 2560 (A.D. 2017). This checklist shall be submitted with Bids.

Project : .....

State Agency: Electricity Generating Authority of Thailand

Bidder Name : .....

Item	Yes	No	Reference (Please specify Article)
1. Bidders have any written anti-corruption policies and guidelines which have been communicated to all levels of employees.			
2. Bidders impose penalty or regulations against corruption.			
3. Bidders have accessible channels or systems to report any suspicions or queries related to corruption.			
4. Bidders have internal personnel or unit explicitly responsible for the prevention of corruption.			

We hereby confirm that all above statements are true and correct.

Signed

\_\_\_\_\_  
(Name of Bidder)  
(Authorized person)  
Stamp company seal (if any)

# **ELECTRICITY GENERATING AUTHORITY OF THAILAND**

Nonthaburi  
Thailand

**INVITATION TO BID NO. TILS-L-02**  
**SUPPLY AND CONSTRUCTION OF TRANSMISSION LINE**  
**500 kV THUNG SONG - SONGKHLA 3**  
**(FROM THUNG SONG TO KM. 105)**

**TRANSMISSION SYSTEM IMPROVEMENT PROJECT IN**  
**LOWER SOUTHERN REGION TO ENHANCE SYSTEM SECURITY**  
**(TWO-ENVELOPE)**

---

## **Invitation**

The Electricity Generating Authority of Thailand (EGAT) hereby invites sealed bids for Supply and Construction of Transmission Line 500 kV Thung Song – Songkhla 3 (from Thung Song to KM. 105) under Transmission System Improvement Project in Lower Southern Region to Enhance System Security Project in accordance with the Terms and Conditions, Technical Specifications and Drawings described in these Bidding Documents.

## **Work Description**

The transmission line to be supplied and constructed under this Invitation is 500 kV, 50 Hz, 3 phase, quad-bundled conductor per phase on double circuit self-supporting lattice steel towers extending from Thung Song Substation (KM. 0) to KM. 105, having a distance of approximately 105 kilometers in length as the first section of the 500 kV Thung Song – Songkhla 3 Transmission Line in the southern region of Thailand with a total distance of approximately 211 kilometers. This transmission line will be located on the new right-of-way with 30 meters in width on each side of the center line of the transmission line.

Please note that the second section of the whole 500 kV Thung Song–Songkhla 3 Transmission Line to be constructed from KM. 105 to Songkhla 3 Substation will be undertaken under Invitation to Bid No. TILS-L-06. The Contractor of Invitation to Bid No. TILS-L-06 shall also be responsible for the work at the connection point for both sections which is shown in the Drawing No. T05-001 : Interfacing Work.

The conductor to be employed under this Invitation will be 1272 MCM ACSR/GA supplied by EGAT. Two types of shield wires will be employed for this Contract ; one of which is 3/8 inch nominal diameter, extra high strength galvanized steel

shield wire and the other is composite overhead ground wire with 36-core optical fiber. Both types of shield wires shall be supplied by the Contractor.

All types of steel towers and foundation towers have already been designed by EGAT. Furthermore, the fabrication / erection drawings as well as stub & setting dimensions and details & bar bending schedule of foundations for all tower types will be prepared and provided to the Contractor by EGAT.

However, the Contractor shall also note that the detailed fabrication / erection drawings for some tower leg extensions as well as stub & setting dimensions for some tower types may not be available or some modifications to EGAT's furnished details & bar bending schedule of foundations may be required. In such case, the Contractor shall perform and provide these drawings for EGAT's approval.

Detailed fabrication / erection drawings of steel towers provided by EGAT will be furnished to the Contractor after confirmation of Letter of Award of Contract. The Contractor shall carefully scrutinize EGAT's furnished detailed fabrication / erection drawings, make minor modifications as necessary and submit all revised drawings to EGAT for review and approval. The full responsibility for adequacy and accuracy of all detailed drawings shall rest with the Contractor and he shall have no right to claim for additional compensation as a result of his misinterpretation or failure to check the drawings for compliance with the design requirements, inaccuracies, errors and omissions.

Reproducible drawings and CD-ROM of EGAT's furnished detailed fabrication / erection drawings of steel towers will not be required. The approved drawings, reproducible drawings and CD-ROM of these steel towers required to be submitted for this Contract shall therefore be bill of material. However, in case the Contractor makes modifications to EGAT's furnished detailed fabrication / erection drawings of steel towers or details & bar bending schedule of foundations or prepares drawings of which leg extensions and/or stub & setting dimensions are not available, such drawings shall be submitted for EGAT's approval and therefore reproducible drawings and CD-ROM of these drawings shall be required.

The Contractor shall also be responsible for the design of any other necessary parts for completion of the Work, including the manufacture, supply, testing, construction and installation of the various components of the transmission line. The portion of design and detailing which are provided by EGAT is not under the Contractor's design responsibility.

Services required to complete the Work are shown in the Bid Price Schedules and included in these Bidding Documents.

## **Eligibility of Bidders: General Requirements**

I. All Bidders shall meet the following requirements; failure to so comply shall constitute sufficient ground for rejection.

- a. The Bidder shall be a partnership, firm or company, either alone or in joint venture or in consortium.
- b. The Bidder shall be well-established and maintain a permanent place of business.
- c. The Bidder shall not be, or supply the Equipment, from the country under the state of Civil War.
- d. The Bidder shall not be named in the List of Work Abandoners published by the Permanent Secretary, Ministry of Finance and/or in the Debarment List and/or in the List of Work Abandoners declared by EGAT.
- e. The Bidder shall not be a Jointly Interested Bidder with other Bidders as from the date of EGAT's issuance of the Invitation to Bid, or shall not be a person who undertakes any action as an "Obstruction of Fair Price Competition" as defined in Additional Regulation for this Invitation.
- f. The Bidder shall not either be EGAT's consultant or involving in EGAT's consultancy company under this Invitation, or have EGAT's personnel involved in his business as shareholder having voting right that can control his business, director, manager, officer, employee, agent or consultant except the ones who are officially ordered by EGAT to act or participate therein.
- g. The Bidder shall not be the person who is privileged or protected not to be taken any legal proceedings under Thai Court; provided that such Bidder's government declares that such special privilege is waived.
- h. In case of being a joint venture or a consortium, the Bidder shall carry out all the Work under such formation from the time of bidding until the fulfillment of the Contract.
- i. The Bidder shall be a purchaser of the bidding documents from EGAT. For a joint venture or consortium, only one (1) member of the joint venture or consortium is required to purchase the bidding documents.***

***In the case where the Bidder is not the purchaser of the bidding documents, the purchaser shall notify EGAT of the name of the Bidder in writing prior to the bid opening.***

II. All Bidders should preferably meet the following requirements; failure to so comply may constitute sufficient ground for rejection.

- a. The Bidder shall have adequate funds to meet financial obligations incidental to this Contract.
- b. The Bidder shall supply documentary evidence established in accordance with Article B-8. Information to be Submitted with Bid to demonstrate adequately that he is eligible to bid and is qualified to perform the Contract if his bid is accepted. Bidder should also demonstrate his capacity to perform the Work either with or without the use of subcontractor.

### **Eligibility of Bidders: Technical Requirements**

#### **I. All Bidders shall meet the following requirements; failure to so comply shall constitute sufficient ground for rejection.**

- a. The Bidder shall be named in EGAT Accepted Bidders List for Supply and Construction of Transmission Line : 500 kV Transmission Line with Four-bundled Conductor. The said Accepted List is attached at the end of Section A. Invitation to Bid.
- b. For Insulator for conductor, the manufacturer shall be named in EGAT Accepted Manufacturers List for Insulator Fog Type and/or Standard Type attached at the end of Section A. Invitation to Bid.

OR

In case EGAT Accepted Manufacturers List is not attached herewith, the manufacturer shall have the qualifications as follows :

- 1) Insulator for conductor manufacturer shall be a regular manufacturer of excellent reputation having significant technical knowledge and at least three (3) years experience in the design, manufacture and testing of the Equipment, having manufacturing capacity available to perform the Work properly and expeditiously within the time specified, and having satisfactory past experience.
- 2) Insulator for conductor manufacturer shall have a record of three (3) consecutive years of successful operation/use of at least 100,000 units of insulator ANSI Class 52-8 or similar and at least 20,000 units of insulator ANSI Class 52-11 or similar in transmission line(s) operated in the transmission network electric utility in overseas country (not his own country) at a voltage level of 400 kV or higher during the last ten years.
- c. Proposing towers, conductor, hardware assemblies and line accessories for conductor, rigid spacers and spacer dampers for conductor, and composite overhead ground wire with optical fiber (OPGW)



manufactured by regular manufacturers of excellent reputation having significant technical knowledge and at least three (3) years experience in the design, manufacture and testing of such Equipment, having manufacturing capacity available to perform the Work properly and expeditiously within the time specified, and having satisfactory past experience, with additional requirements as follows:

- 1) Tower manufacturer being an eligible local firm having set up a plant for fabrication of steel towers in Thailand
- 2) Hardware assemblies and line accessories for conductor manufacturer being an eligible local firm having set up a plant in Thailand
- 3) Rigid spacer for conductor manufacturer being an eligible local firm having set up a plant in Thailand
- 4) Spacer dampers for conductor manufacturer having a record of five (5) consecutive years of successful operation/use of the same or similar type as those required under this Invitation and used in multi but not less than four-bundled conductor transmission lines operated at a voltage level of 400 kV or higher having accumulated circuit distance of not less than 200 kilometers
- 5) Composite overhead ground wire with optical fiber (OPGW) manufacturer having a record of at least three (3) consecutive years of successful operation/use of the same or similar type as those required under this Invitation in the transmission line having accumulated distance of not less than 20 kilometers
- 6) For proposed conductor, according to the Industrial Product Standards Act B.E. 2511 which stipulates that the conductor is an industrial product that is required to conform with the Thai Industrial Standards – TIS 85-2548;

In case of locally supplied conductor, the manufacturer of the conductor shall receive a license from the Industrial Product Standards Council, Ministry of Industry, for manufacture of the industrial product and use of a standard mark, and

In case of foreign supplied conductor, the conductor shall be imported by a person having received a license from the Industrial Product Standards Council, Ministry of Industry, for importation of the industrial product.

However, the Bidder may propose any qualified local manufacturer who does not have experience in design, manufacture and testing as well as a record of successful operation/use of his Equipment as specified above but has obtained special permission from EGAT for manufacture and/or fabrication of the specific Equipment within the scope specified in the letter of permission issued by EGAT, or propose any local manufacturer who is in the list of Eligible Local Manufacturers Accepted by EGAT as shown herein at the end of this Section.

In the event that the Bidder proposes the Equipment of the manufacturer who, at the time of bidding, fails to meet with requirements of any contract(s) with EGAT regarding major defects or malfunctioning of such Equipment, and such failure has not yet satisfactorily been proved to and/or settled with EGAT, EGAT reserves the right to reject his Bid. This eligibility will not be applicable for any Equipment which is not required under this Invitation.

**II. All Bidders should preferably meet the following technical requirements; failure to so comply may constitute sufficient ground for rejection.**

- a. Having sufficient capacity to carry out the Work.
- b. Proposing shield wire, insulators for shield wire and for OPGW, hardware assemblies and line accessories for shield wire and for OPGW, grounding materials, fiber optic transmission system Equipment, and other Equipment manufactured by regular manufacturers of excellent reputation having significant technical knowledge and at least three (3) years experience, in the design, manufacture and testing of such Equipment, having manufacturing capacity available to perform the Work properly and expeditiously within the time specified, and having satisfactory past experience, with additional requirements as follows:
  - Manufacturers for shield wire (zinc-coated extra high strength steel wire), hardware assemblies and line accessories for shield wire and for OPGW, and non-metallic optical fiber cable (OFC) being an eligible local firm having set up a plant in Thailand

However, the Bidder may propose any qualified local manufacturer who does not have experience in design, manufacture and testing as well as a record of successful operation/use of his Equipment as specified above but has obtained special permission from EGAT for manufacture and/or fabrication of the specific Equipment within the scope specified in the letter of permission issued by EGAT, or propose any local manufacturer who is in the list of Eligible Local

Manufacturers Accepted by EGAT as shown herein at the end of this Section.

In the event that the Bidder proposes the Equipment of the manufacturer who, at the time of bidding, fails to meet with requirements of any contract(s) with EGAT regarding major defects or malfunctioning of such Equipment, and such failure has not yet satisfactorily been proved to and/or settled with EGAT, EGAT reserves the right to reject this Bid.

This eligibility will not be applicable for any Equipment which is not required under this Invitation.

- c. Proposing reputable subcontractors, for the portion of the Work to be subcontracted, having adequate technical knowledge, ability and capacity and practical experience to perform such work. If any proposed subcontractor(s) is (are) not qualified in the opinion of EGAT, the Bidder is required to select other subcontractor(s) at his own cost to the satisfaction of EGAT.
- d. Having no just or proper claims pending against him with respect to breach in the performance of Contract on other similar works awarded by EGAT. If Bidder is a new company formed by acquisition of or merger with other companies or business units, the pending claim of any of such previous companies or business units shall be considered pending claim of the Bidder.
- e. Himself or his subcontractors, at the time of submitting this proposal, not carrying excessive work or not being in a default position with respect to work with EGAT. Unsatisfactory past performance on contract awarded by EGAT may be a sufficient reason of being disqualified.

Reference records of either the parent or affiliated companies shall not be considered as the records of such Bidder or manufacturers.

\*\*\*\*\*

**EGAT Accepted Bidders List**  
**for Supply and Construction of Transmission Line**  
**500 kV Transmission Line with Four-bundled Conductor**

No.	Bidder/Country
1	Consortium of J-Power Systems Corporation and Thai Sumiden Engineering and Construction Co., Ltd. (J-Power Systems Corporation / Japan and TSEC (Thailand) Co., Ltd. / Thailand)
2	Fujikura Ltd. / Japan
3	The Consortium of Kalpataru and CHC (Kalpataru Power Transmission Ltd. / India and CHC Engineering Co., Ltd. / Thailand)
4	DEMCO-COBRA-RCR CONSORTIUM (Demco Public Company Limited / Thailand, Cobra Instalaciones Y Servicios, S.A. / Spain and RCR Company Limited / Thailand)
5	DEMCO-COBRA Consortium (Demco Public Co., Ltd. / Thailand and Cobra Instalaciones Y Servicios, S.A. / Spain)
6	KEC INTERNATIONAL LIMITED / India
7	LARSEN & TOUBRO LIMITED / India
8	SEPCO1 Electric Power Construction Corporation / China
9	THE CONSORTIUM OF PRECISE SYSTEM AND PROJECT CO., LTD AND THAI SUMIDEN ENGINEERING AND CONSTRUCTION CO., LTD. (PRECISE SYSTEM AND PROJECT CO., LTD / Thailand and TSEC (THAILAND) CO., LTD. / Thailand)
10	Hyundai Engineering & Construction Co., Ltd. / Korea
11	RCR Co., Ltd. / Thailand
12	The Joint Venture of Hydrochina International Engineering Co., Ltd. and Benyapha Powerline Co., Ltd. and SEPCO1 Electric Power Construction Corporation (Hydrochina International Engineering Co., Ltd. / China, Benyapha Powerline Co., Ltd. / Thailand and SEPCO1 Electric Power Construction Corporation / China)
13	TPL-TEDA Consortium (TATA Projects Limited / India and TEDA Company Limited / Thailand)
14	Joint Venture of SCL and Benyapha and SEPCO1 (Sinohydro (Thailand) Co., Ltd. / Thailand and Benyapha Powerline Co., Ltd. / Thailand and SEPCO1 Electric Power Construction Corporation / China)
15	The Consortium of Kalpataru Power Transmission Limited, Precise System and Project Company Limited and Thai Sumiden Engineering and Construction Company Limited (Kalpataru Power Transmission Limited / India, Precise System and Project Company Limited / Thailand and TSEC (Thailand) Co., Ltd. / Thailand)

No.	Bidder/Country
16	Consortium of Loxley, Larsen & Toubro and Sri U-Thong (Loxley Public Company Limited / Thailand, Larsen & Toubro Limited / India and Sri U-Thong Limited / Thailand)
17	Demco - RCR CONSORTIUM (Demco Public Company Limited / Thailand and RCR Company Limited / Thailand)
18	Joint Venture of XD-HYPEC-SCL-TNP (XIAN ELECTRIC ENGINEERING CO., LTD. / China, HUBEI HONGYUAN POWER ENGINEERING CO., LTD. / China, SINOHYDRO (THAILAND) CO., LTD. / Thailand and TNP POWER THAI CO., LTD. / Thailand)
19	Consortium of Larsen & Toubro Limited and Sri U-Thong Limited (Larsen & Toubro Limited / India and Sri U-Thong Limited / Thailand)
20	CONSORTIUM OF LARSEN & TOUBRO, LPS AND SRI U-THONG (LARSEN & TOUBRO LIMITED / India and LOXLEY POWER SYSTEM CO., LTD. / Thailand and Sri U-Thong Limited / Thailand)
21	JOINT VENTURE OF STC, XD AND BENYAPHA (SINOHYDRO (THAILAND) CO., LTD. / Thailand, XIAN ELECTRIC ENGINEERING CO., LTD. / China and BENYAPHA POWERLINE CO., LTD. / Thailand)
22	TSEC (Thailand) Co., Ltd. / Thailand
23	JOINT VENTURE OF XD AND STC (Xian Electric Engineering Co., Ltd / China and Sinohydro (Thailand) Co., Ltd. / Thailand)
24	Sri U-Thong Limited / Thailand
25	Henan Electric Power Transmission & Transformation Construction Co., Ltd. / China
26	Kalpataru Power Transmission Limited / India
27	HS Consortium (Hydro Engineering Co., Ltd. / Thailand and Sinotec Co., Ltd. / China)
28	SRI U-THONG & LPS CONSORTIUM (Sri U-Thong Limited / Thailand and Loxley Power Systems Co., Ltd. / Thailand)
29	Benyapha Power Line Co., Ltd. / Thailand
30	Joint Venture of STC and BENYAPHA (Sinohydro (Thailand) Co., Ltd. / Thailand and Benyapha Powerline Co., Ltd. / Thailand)
31	Demco Public Company Limited / Thailand
32	Joint Venture of STC-BENYAPHA-NEPC (Sinohydro (Thailand) Co., Ltd. / Thailand, Benyapha Powerline Co., Ltd. / Thailand and NEPC Power Construction Co., Ltd. / Thailand)

**ELIGIBLE LOCAL MANUFACTURERS ACCEPTED BY EGAT**

The following local manufacturers are eligible for proposing each specific equipment for this Invitation; provided that the scope of their offerings shall be within that specified in the Certificate of Acceptance issued by EGAT.

**1) STEEL TOWERS**

**Ajikawa & SCI Metal Tech Co., Ltd.**

49/1 Moo 9, Marppong  
Phantong  
Chonburi 20160  
Tel : 038 451 473-6  
Fax : 038 451 478

**Siam Steel Tower Co., Ltd.**

9/10 Moo 10 Tambol Koke-Yae  
Amphur Nong Khae  
Saraburi 18230, Thailand  
Tel : (662) 705-8755-63  
Fax : (662) 705-8765

**Thai-Scandic Steel Company Limited**

7 I-5 Road, Maptaphut Industrial Estate  
Amphur Muang  
Rayong 21150  
Tel : (66-38) 683070  
Fax : (66-38) 683065

**UA WITHYA PUBLIC COMPANY LIMITED**

247 Romklao Road  
Saensaeb  
Minburi, Bangkok 10510  
Thailand  
Tel : 662-543-9020-8  
Fax : 662-915-2114, 915-2714, 543-9029

**Demco Power Company Limited**

59 Moo 1, Suanphrikthai  
Muangpathumthani  
Pathumthani 12000  
Tel : 0 2959 5811 Ext.1612  
Fax : 0 2959 5915

tse  
เอกสารควบคุม

2) **HARDWARE ASSEMBLIES AND LINE ACCESSORIES FOR CONDUCTOR, OVERHEAD GROUND WIRE AND OPGW**

**Preformed Line Products (Thailand) Ltd.**

296 Moo 4, Lardkrabang Industrial Estate  
EPZ 3 Chalongkrung Road  
Lumphatew, Lardkrabang  
Bangkok 10520  
Tel : 0 2739 4026  
Fax : 0 2326 0564

- (For 1. Hardware assemblies and line accessories (except damper) for single, twin-bundled and quad-bundled conductor for 115 kV, 230 kV and 500 kV transmission lines
2. Hardware assemblies and line accessories (except damper) for overhead ground wire and OPGW
  3. Vibration dampers for conductor, overhead ground wire and OPGW
  4. Spacer dampers and rigid spacers for twin-bundled and quad-bundled conductor for 115 kV, 230 kV and 500 kV transmission lines)

**MacLean - Dulhunty Power (Thailand) Ltd.**

3/2 Moo 7 Suwintawong Road  
Tambon Klounguangphang  
Amphur Muang Chachoengsao  
Chachoengsao 24000  
Tel : 038 845 675  
Fax : 038 845 674

- (For 1. Hardware assemblies and line accessories (except damper) for single, twin-bundled and quad-bundled conductor for 115 kV, 230 kV and 500 kV transmission lines
2. Hardware assemblies and line accessories (except damper) for overhead ground wire and OPGW
  3. Vibration dampers for conductor, overhead ground wire and OPGW
  4. Spacer dampers and rigid spacers for twin-bundled and quad-bundled conductor for 115 kV, 230 kV and 500 kV transmission lines)

**Mosdorfer (Thailand) Co., Ltd.**

94 T, Shinnawatra Building  
3<sup>rd</sup> floor, Sukhumvit Soi 23  
Klong Toey Nua, Wattana  
Bangkok 10110  
Tel : 0 2706 6717  
Fax : 0 2706 6716

- (For 1. Hardware assemblies and line accessories (except damper) for single, twin-bundled and quad-bundled conductor for 115 kV, 230 kV and 500 kV transmission lines
2. Hardware assemblies and line accessories (except damper) for overhead ground wire and OPGW

3. Vibration dampers for conductor, overhead ground wire and OPGW
4. Spacer dampers and rigid spacers for twin-bundled and quad-bundled conductor for 115 kV, 230 kV and 500 kV transmission lines)

It shall be noted that the spacer damper for quad-bundled conductor for 500 kV transmission line is allowed to be initially supplied to only one contract. Any further contracts shall be allowed after the said Equipment under the first contract has been certified by a certification issued by EGAT for its successful operation in EGAT's transmission line for an appropriate period of time.

**3) OVERHEAD GROUND WIRE**

**Thai Wire Products Public Company Limited**

99/2 MOO 8 ZEER STREET BUILDING 7TH FL  
Phahonyothin Road, Lamlookka  
Pathum Thani 12130  
Tel : 0 2992 6863-7  
Fax : 0 2992 6870-1

**USHA Siam Steel Industries Public Company Limited**

209/1 K-Tower-B. 22<sup>nd</sup> Floor  
Unit 3/1 Sukhumvit 21 Road (Asok)  
Bangkok 10110  
Tel : 0 2261 7361-4  
Fax : 0 2640 8227

**Charoong Thai Wire & Cable Public Company Limited**

589/71 Central City Tower  
Floor 12A, Bangna -Trad Road  
Bangna, Bangna District  
Bangkok 10260  
Tel : 0 2745 6118  
Fax : 0 2745 6131-32

**4) GROUNDING MATERIALS**

**K.M.L. Technology Co., Ltd.**

100/3 Thasabansongkrow Road  
Ladyao, Jatujak  
Bangkok 10900  
Tel : 0 2954 3455  
Fax : 0 2591 7891

**5) CONDUCTOR**

**Bangkok Cable Co., Ltd.**

187/1 Rajdamri Road  
Lumpinee, Pathumwan  
Bangkok 10330  
Tel : 0 2254 4550-6  
Fax : 0 2253 5973, 0 2253 6028, 0 2254 3859



**Charoong Thai Wire & Cable Public Company Limited**

589/71 Central City Tower  
Floor 12A, Bangna -Trad Road  
Bangna, Bangna District  
Bangkok 10260  
Tel : 0 2745 6118  
Fax : 0 2745 6131-32

**Phelps Dodge International (Thailand) Limited**

16<sup>th</sup> Floor, Maneeya Center Building  
518/5 Ploenchit Road  
Lumpinee, Pathumwan  
Bangkok 10330  
Tel : 0 2652 0588, 0 2680 5862  
Fax : 0 2680 5896

**Thai-Yazaki Electric Wire Co., Ltd.**

27<sup>th</sup> Floor, Two Pacific Place Building  
142 Sukhumvit Road  
Klongtoey District  
Bangkok 10110  
Tel : 0 2653 2550, 0 2463 0058 Ext. 342  
Fax : 0 2463 6364, 0 2463 6354-5

**Venine Cable Electric Wire Company Limited**

88/8-9 Moo 2 Ladbualueang-Maitra Rd.  
Ladbualueang, Ladbualueang,  
Ayutthaya 13230  
Tel : 0 3528 0493  
Fax : 0 3528 0494

**6) NON-METALLIC OPTICAL FIBER CABLE (OFC)**

**Thai China Fiber Optics Co., Ltd.**

488 Soi Ratchadapisek 26,  
Samsennog, Huaykwang,  
Bangkok 10310  
Tel : 0 2975 9901  
Fax : 0 2975 9925


**Thai Fiber Optics Co., Ltd.**

233 Moo 6, Soi Watchangrueng,  
Suksawat Road,  
Naiklongbangplakot, Phrasamutchedi,  
Samutprakarn 10290  
Tel : 0 2817 5590-3  
Fax : 0 2817 5311

**HBC Telecom Co., Ltd.**

187/1 Rajadamri Road,  
Lumpinee, Pathumwan  
Bangkok 10330  
Tel : 0 2650 5002 To 3 Ext.111,112  
Fax : 0 2651 9261

44



✍

**Siam Fiber Optics Co., Ltd.**  
Floor 12 A, Central City Tower  
589/71 Bangna-Trad Road, Km.3  
Bangna, Bangna,  
Bangkok 10260  
Tel : 0 2745 6118-30  
Fax : 0 2745 6575

**SECTION H  
ATTACHMENTS**

Attachment No. 1 : List of Equipment to be Furnished by EGAT

280  
10/6

**ATTACHMENT NO. 1**

**LIST OF EQUIPMENT TO BE FURNISHED BY EGAT**

The Equipment listed herein shall be furnished by EGAT in Bangkok and/or its vicinity, at the point to be designated by EGAT as soon as possible after confirmation of Letter of Award of Contract. Any Equipment not listed herein but required for construction for completion of the Work shall be furnished by the Contractor at his own expenses.

<b><u>Item</u></b>	<b><u>Description</u></b>	<b><u>Estimated Quantity</u></b>
1.	1272 MCM ACSR/GA conductor as per Schedule 1E, Item 1E1.1	2,558.40 km

- Note :**
1. The estimated quantity of conductor shown above is an approximate amount. The actual quantity of conductor to be furnished by EGAT will be in accordance with the actual horizontal distance of the section to be installed after checking survey and staking have been performed, Plus a Fixed extra of 1.5 percent to cover sag, terrain irregularities and wastage.
  2. The conductor furnished will have characteristics as specified in Specification No. L-500 kV, Section B : Conductor

\* 287  
\* 167 \*