

ELECTRICITY GENERATING AUTHORITY OF THAILAND

Supplemental Notice No. 1

Invitation to Bid No. NPUP-SA-02 and LPLC-SA-01 and TIEC-SA-05

Supply of Surge Arrester

**Transmission System Development in the Area of
Nan Phrae and Uttaradit Provinces for Power Purchase from Lao PDR Projects
Long-Term Investment Plan to Accommodate Large Power Consumer
Transmission System Improvement Project in Northeastern, Lower Northern,
Central Regions and Bangkok Area to Enhance System Security**

The attached Supplemental Notice shall be considered as part of the bidding documents No. NPUP-SA-02 and LPLC-SA-01 and TIEC-SA-05.

As acknowledgement of receipt that all additions, deletions and revisions contained in this Supplemental Notice are incorporated into the above bidding documents, Bidder is requested to sign and return this acknowledgement via email address : chulalak.sap@egat.co.th within three (3) days from the date of the announcement of this Supplemental Notice on <http://www4.egat.co.th/fprocurement/biddingeng/>.

The original acknowledgement which is manually signed in ink by a person or persons duly authorized shall be included in the proposal to be submitted on the bid opening date.

ELECTRICITY GENERATING AUTHORITY OF THAILAND

June 22, 2026

ACKNOWLEDGEMENT

This undersigned Bidder hereby certifies that the additions, deletions and revisions set forth in this Supplemental Notice to Invitation to Bid No. TIEC-RX-04 are incorporated as part of the above bidding documents and will be fully included in any bids which he may submit.

Signed _____

Title _____

Company _____

Date _____

ELECTRICITY GENERATING AUTHORITY OF THAILAND

SUPPLEMENTAL NOTICE NO. 1

INVITATION TO BID NO. NPUP-SA-02 and LPLC-SA-01 and TIEC-SA-05

SUPPLY OF SURGE ARRESTER

TRANSMISSION SYSTEM DEVELOPMENT IN THE AREA OF
NAN PHRAE AND UTTARADIT PROVINCES FOR POWER
PURCHASE FROM LAO PDR PROJECTS

LONG-TERM INVESTMENT PLAN TO ACCOMMODATE
LARGE POWER CONSUMER

TRANSMISSION SYSTEM IMPROVEMENT PROJECT IN
NORTHEASTERN, LOWER NORTHERN, CENTRAL REGIONS
AND BANGKOK AREA TO ENHANCE SYSTEM SECURITY

The following supplemental information is hereby given for the above described Invitation:

Section G : Ratings and Features

Replace page G3 of Ratings and Features No. SA7Y1A with the revised page with (Rev.1) attached.

Bid submitted must be in accordance with this Notice. Receipt of this Notice shall be acknowledged by the Bidder on the proposal included in the Bidding Documents in the space provided on page C3, Article C-7 Supplemental Notices.

ELECTRICITY GENERATING
AUTHORITY OF THAILAND

..... June 22 , 2026

**Surge Arrester
Specification No. 741**



**Substation Electrical
Equipment Engineering Department**

Ratings and Features	Designed : via ECM system	Validated : via ECM system	Revision 1	Page 1/1
RF No. SA7Y1A	Verified : via ECM system	Approved : via ECM system	Dated : 16/06/2026	

a. Type	Metal Oxide without series gaps
b. Class	Station Class
c. Rated Frequency	50 Hz
d. Nominal System Voltage	115 kV
e. Highest Voltage for Equipment	123 kV
f. Arrester Voltage Rating	≥ 108 kVrms
g. Insulator	<input checked="" type="checkbox"/> Porcelain <input type="checkbox"/> Polymer
h. Repetitive Charge Transfer Rating (Qrs)	≥ 2.0 C
i. Thermal Energy Rating (Wth)	7 kJ/kV
j. Rated Short Circuit Current	63 kA
k. Maximum Lightning Impulse Residual Voltage	242 kV crest @ 5 kA 256 kV crest @ 10 kA 276 kV crest @ 20 kA
l. Maximum Switching Impulse Residual Voltage	219 kV crest @ 0.5 kA
m. Minimum Creepage Distance	≥ 3075* mm
n. Discharge Counter	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
o. Mounting	As price schedule
p. Line Terminals	4-Hole NEMA Pad
q. Applicable Standard	IEC 60099-4

Note: *Special Creepage Distance ; Base on 25 mm/kVmax.L-L